


SPIGOT TO SUIT CLIENT APPLICATION

25 - 20 REDUCER CABLE ENTRY

Ø88.9 (COLUMN O.D)



DOOR CLEARANCES

88.9 OD GALVANISED PIPE

ACCESS DOOR WITH FUSE STRAP BEHIND

GROUND LEVEL

200 x 40mm CONDUIT SLOTS

COLUMN WEIGHT: 37KG's

STANDARDS

- ALL PRODUCTS TO CONFORM TO THE FOLLOWING AUSTRALIAN STANDARDS
- * AS 1170.2: Structural design actions - Wind actions.
 - * AS 1302: Geometrical product specifications indication of surface texture in technical production documentation.
 - * AS 1554(set) Structural steel welding set.
 - * AS 2159: Piling - Design & Installation.
 - * AS 2870: Residential slab footings - Construction.
 - * AS 3600: Concrete structures.
 - * AS 3678: Structural steel - Hot rolled plates, floorplates and slabs.
 - * AS 4680: Hot dip galvanized (Zinc) Coatings on fabricated ferrous articles.
 - * AS/NZS 4671: Steel reinforcing materials.
 - * AS/NZS 4600: Cold formed steel structures.
 - * AS/NZS 4676: Structural design requirements for utility services poles.



G&S Industries

97 GUTHRIE STREET OSBORNE PARK W.A. 6017
PH. (08) 9446 8044, (08) 9446 8266
FAX (08) 9446 5456

JOB No	DATE	DESIGN: SG	DRAWN: ZL
POST TOP COLUMN C88D4.4		CHECKED: RG	APPROVED: Y
88.9 OD		LAST REVISED: 4 SEPT '06	
4400mm		SCALE: NTS	
650011		DRAWING: ZLRG2105	REVISION: 01